



Product certificate K-0221866-1

Issued 2025-04-01
Replaces -
Page 1 of 2

Drinking water system components – health effects according to NSF/ANSI/CAN 61

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the product:

Axial control, on/off and check valves

supplied by

Mokveld Valves B.V.

as specified in this product certificate and marked with the Kiwa NSF/ANSI 61 in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline Manual K15007 for “drinking water system components – health effects according to NSF/ANSI/CAN 61”, dated 01 May 2024.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.com in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchilllaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@kiwa.com
www.kiwa.com

Company

Mokveld Valves B.V.
Nijverheidsstraat 67
2802 AJ GOUDA
The Netherlands
Tel +31 18 259 75 00
www.mokveld.com



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Drinking water system components – health effects according to NSF/ANSI/CAN 61**Product specification**

The product mentioned below belongs to this certificate

Product	Size	Water Contact Temp	Water Contact Material
Axial control, on/off and check valves	Axial Control valve 4"-48" On-off valve 4"-48" Check valve 4"-56"	[1]	Multiple
[1] Application for intended use in continuous exposure to drinking water with a maximum end-use temperature of 60 ± 2 °C (140 ± 4 °F).			

Hygienic aspects*Approval:*

This product is approved on the basis of the requirements set in NSF/ANSI/CAN 61.

Kiwa NSF/ANSI/CAN 61 criteria:

The product certification is based on two main criteria. The product shall permanently comply with:

- the product recipe approved during the assessment procedure. The recipe is laid down for the confidentiality reasons undisclosed in the appendix to certificate K-0221866. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- specific product requirements for the hygienic aspects, laid down in the appendix to certificate K-0221866. For confidentiality reasons this appendix is not public.

Marking

After entering into a Kiwa certification agreement, the certified products shall be clearly and indelibly marked with the certification mark¹⁾:



Or words **KIWA NSF/ANSI 61**¹⁾

¹⁾ If not possible the marking shall be on the smallest packaging

Mandatory marks:

- "Mokveld Valves B.V."
- Product identification (trade name or product type)
- Production code
- "K-0221866"

The realization of the marks as is follows: clearly and indelible.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Mokveld Valves B.V.
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.